

SUGGESTED SPECIFICATIONS
SECTION 09 72 00
C/S Acrovyn® Saratoga™ Wall System

Part 1 - General

1.01 Summary

- A. This section includes the following types of wall protection systems:
 - 1. Wall Covering
- B. Related sections: The following sections contain requirements related to this section:
 - 1. Handrails, Bumper Guards, Crash Rails, Corner Guards, Accent Rails, Wall Panels, Door Protection; refer to section 10 26 00 “Wall and Door Protection”

1.02 References

- A. National codes (IBC, UBC, SBCCI, BOCA and Life Safety)
- B. American Society for Testing and Materials (ASTM)
- C. Underwriters Laboratories (UL)

1.03 Submittals

- A. General: Submit the following in accordance with conditions of contract and Division 1 specification section 01 33 00 “Submittal Procedures”.
- B. Product data and detailed specifications for each system component and installation accessory required, including installation methods for each type of substrate.
- C. Shop drawings showing locations, extent and installation details of wall covering products.
- D. Samples for verification purposes: Submit the following samples, as proposed for this work, for verification of color, texture, pattern and thickness:
 - 1. Sample of each product specified.
- E. Product test reports from a qualified independent testing laboratory showing compliance of each component with requirements indicated.
- F. Maintenance data for wall protection system components for inclusion in the operating and maintenance manuals specified in Division 1.

1.04 Quality Assurance

- A. Installer qualifications: Engage an installer who has no less than 3 years experience in installation of systems similar in complexity to those required for this project.
- B. Manufacturer’s qualifications: Not less than 5 years experience in the production of specified products and a record of successful in-service performance.
- C. Code compliance: Assemblies should conform to all applicable codes including IBC, UBC, SBCCI, BOCA and Life Safety.
- D. Fire performance characteristics: Provide wall protection system with UL label indicating that they are identical to those tested in accordance with ASTM-E84 (CAN/ULC S102.2) for Class 1 characteristics listed below:
 - 1. Flame spread: 25 or less
 - 2. Smoke developed: 450 or less

International Fire Ratings Include:

UK: BS476-part 7, Class 1.

France: MI.

Spain: MI.

Germany: DIN4102, BI Classification.



Italy: Class 1.

- E. Impact Strength: Provide assembled wall protection units that have been tested in accordance with the applicable provisions of ASTM F476.
- F. Chemical and stain resistance: Provide wall protection system components with chemical and stain resistance in accordance with ASTM D-1308.
- G. Color match: Provide wall protection components that are color matched in accordance with the following:
 - 1. Delta Ecmc of no greater than 1.0 using CIELab color space. (Specifier note: Construction Specialties' colors are matched under cool white fluorescent lighting and computer controlled within manufacturing tolerances. Color may vary if alternate lighting sources are present.)
- H. Single source responsibility: Provide all components of the wall protection system manufactured by the same company to ensure compatibility of color, texture and physical properties.

1.05 Delivery, Storage and Handling

- A. Deliver materials to the project site in unopened original factory packaging clearly labeled to show manufacturer.
- B. Store materials in original, undamaged packaging in a clean, dry place out of direct sunlight and exposure to the elements. A minimum room temperature of 40°F (4°C) and a maximum of 100°F (38°C) should be maintained.
- C. Materials must be stored flat.

1.06 Project Conditions

- A. Materials must be acclimated in an environment of 65-75°F (18-24°C) for at least 24 hours prior to beginning the installation.
- B. Installation areas must be enclosed and weatherproofed before installation commences.

Part 2 - Products

2.01 Manufacturers

- A. Interior surface protection products specified herein and installed on the submittal drawings shall be manufactured by Construction Specialties, Inc.

2.02 Materials

- A. Modular Wall System to be Acrovyn Saratoga by Construction Specialties Inc: Wall System to be comprised of rigid vinyl/acrylic wall covering .040" (1.02mm) thick with vertical and horizontal moldings manufactured of matching or contrasting .040" (1.02mm) thick vinyl/acrylic wall covering factory bonded to a particle board core.
 - 1. Solid Colored Vinyl/Acrylic Wall Covering: Should be high impact Acrovyn with nominal .040" (1.02mm) thickness and supplied in 4' x 8' or 10' (1.22m x 2.44m or 3.05m) sheet sizes in Pebblette (standard), Suede and Matte textures. Beadboard texture shall be 43" x 90" or 113" (1.09m x 2.29m or 2.87m). The other (7) textures (Sandstone, Mesa, Irish Linen, Leather, Pinstripe, Stone Chips & Stipple) shall be 43" x 90" or 114" (1.09m x 2.29m or 2.90m). Available in (60) solid colors.
 - 2. Chameleon Patterned Vinyl/Acrylic Wall Covering: Should be high impact Acrovyn with nominal .040" (1.02mm) thickness and supplied in 4' x 10' (1.22m x 3.05m) sheet in standard Suede texture. Beadboard texture shall be a

maximum 43" x 113" (1.09m x 2.87m) sheet size. The (7) other textures (Sandstone, Mesa, Irish Linen, Leather, Pinstripe, Stone Chips & Stipple) shall be a maximum 43" x 114" (1.09m x 2.90m) sheet size. Available in (16) Chameleon patterned colorways which include (14) woodgrains and (2) metals.

3. Vinyl/Acrylic Moldings: Vertical and horizontal moldings should be high impact Acrovyn with nominal .040" (1.02mm) thickness factory bonded to a particle board core.
 - a) Vertical moldings to be 3/8" (10mm) thick x 2", 4", 6" or 8" (51mm, 102mm, 152mm or 203mm) wide x 8' (2.44m) long.
 - b) Horizontal moldings, including wainscot and base molding, to be 1/2" (13mm) thick x 2", 4", 6" or 8" (51mm, 102mm, 152mm or 203mm) high x 8' (2.44m) long.
 - c) Inside/outside corners for wainscot application shall be 3/8" (10mm) thick x 2", 4", 6" or 8" (51mm, 102mm, 152mm or 203mm) wide x 8' (2.44m) long.
 - d) Inside/outside corner for full height application shall be 5/8" (16mm) thick x 2", 4", 6" or 8" (51mm, 102mm, 152mm or 203mm) wide x 8' (2.44m) long.
4. Optional Wainscot Molding: Model SRW-260 should be 2-1/4" (57mm) high x 8' (2.44m) long colonial style real wood rail to be painted or stained to match specified color.

2.03 Fabrication

- A. General: Fabricate wall covering to comply with requirements indicated for design, dimensions, detail, finish and sizes.

2.04 Accessories

- A. Acrovyn Saratoga Wall System shall be furnished as a complete packaged system, containing all primers and adhesive. Primer and adhesive materials shall be water based and non-hazardous.

Part 3 - Execution

3.01 Examination

- A. Verification of conditions: Examine areas and conditions under which work is to be performed and identify conditions detrimental to proper or timely completion.

1. Do not proceed until unsatisfactory conditions have been corrected.

3.02 Preparation

- A. Surface preparation: Prior to installation, clean substrate to remove dirt, debris and loose particles. Perform additional preparation procedures as required by manufacturer's instructions.
- B. Protection: Take all necessary steps to prevent damage to material during installation as required in manufacturer's installation instructions.

3.03 Installation

- A. Install the work of this section in strict accordance with the manufacturer's recommendations, using approved adhesive.



- B. Temperature at the time of installation must be between 65-75°F (18-24°C) and be maintained for at least 48 hours after the installation to allow for proper adhesive set up.
- C. Relative humidity shall not exceed 80%.
- D. Do not expose wall covering to direct sunlight during or after installation. This will cause the surface temperature to rise, which in turn will cause bubbles and delamination.

3.04 Cleaning

- A. General: Immediately upon completion of installation, clean wall covering and accessories in accordance with manufacturer's recommended cleaning method.
- B. Remove surplus materials, rubbish and debris resulting from installation as work progresses and upon completion of work.

3.05 Protection

- A. Protect installed materials to prevent damage by other trades. Use materials that may be easily removed without leaving residue or permanent stains.

