# STORM RESISTANT LOUVERS – MODEL RSH–5700




VERTICAL SECTION




PLAN VIEW

## SCREENS

- ☐ SCREEN NOT REQUIRED
- ☐ SCREEN REQUIRED
- ☐ INTERIOR MOUNTED
- ☐ EXTERIOR MOUNTED
- ☐ BIRDSCREEN (¼" MESH)
- ☐ INSECT SCREEN (18 X 16 MESH)

## FINISHES

- ☐ STANDARD MILL
- ☐ DURACOLOR 400
- ☐ KYNAR 500
  - ☐ (1) C/S STANDARD COLORS
  - ☐ CUSTOM COLOR, C/S REQUIRES A COLOR CHIP FOR MATCHING
- ☐ ARCHITECTURAL CLASS I (MED OR DARK) BRONZE ANODIC COATING
- ☐ 204–R1 CLEAR ANODIZE
- ☐ OTHER _____

C/S EXTRUDED ALUMINUM HURRICANE LOUVER 5" DEEP LOUVER MODEL RSH–5700. FRAMES AND BLADES TO BE FABRICATED FROM 6063–T6 ALLOY. FRAME COMPONENTS TO HAVE A NOMINAL .081" MATERIAL THICKNESS. BLADES TO HAVE A .060" MATERIAL THICKNESS.

ALL FASTENERS TO BE STAINLESS STEEL.

UNSUPPORTED BLADE LENGTH = @ PSF.

| MARK | QTY. | "A" DIM. | "B" DIM. | NUMBER OF MULLIONS | LOCATION | REMARKS |
|---|---|---|---|---|---|---|
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | CKD. BY: |

Construction Specialties, Inc.
49 Meeker Avenue
Cranford, New Jersey 07016
(908) 272–5200
Fax (908) 272–6038

| | |
|---|---|
| PROJECT: | DRAWN BY: |
| CUSTOMER: | DATE: |
| ARCH'T: | DWG. NO: |
| AGENT: | SHEET OF |